VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	08 - Kootenay Lake
School Name:	Erickson Elementary
DECUIDEMENT.	Vest
REQUIREMENT:	Yes/ No:
Regular inspection and maintenance of HVAC	Yes
systems	Date of last
	inspection: 2024-
	july
	Date of next
	inspection: 2024- oct
	Date and type of most recent maintenance:
	Filters and belts
	Yes/
	No: Yes
RECOMMENDATION:	
	Detail:
Increase supply of outside air	100% outdoor air until rooms cannot be maintained.
	Yes/
	No: Yes
	Detail (Including filter grade):
RECOMMENDATION:	Merv-13 filters installed
Upgrade filtration, including installing MERV-13 filters, where possible	
RECOMMENDATION:	Yes/
	No:

Use other air cleaning or treatment technologies	Yes Detail: Portable air cleaners used/available when needed.
RECOMMENDATION:	Yes/
Manage energy use and	No:
air distribution through	Yes
building automation control systems	Detail: Direct Digital Controls. (DDC)
011 - 12 - 1	
Other Relevant Information:	
District Contact for any	Name: Chris Kerr
Questions:	Phone Number: 250-354-4871
	Email: Chris.Kerr@sd8.bc.ca